

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Q Dated: 07.08.2026

It is certified that an inspection team headed by

Sbri- M.L. Patel (Name of Officers with designation)

AE PHE Sub. Division Wardha PHED

inspected the Delhi Public School Nigahi

where & address of the school on 07.08.2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 2026/2027/Sgd/830.

On 07.08.2026 of Distt. Lab PHED Singrauli (PHED Lab)

certified that the

Delhi Public School Nigahi (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the required sanitation conditions in the school building & the campus as per norms

prescribed by the Central State U.I. Govt.

This certificate is valid till 06.08.2027.

ASSISTANT ENGINEER
P.H.E. SUB DIVISION

Signature with Seal: M.L. Patel

Name: Sbri- M.L. Patel

Designation: Assistant Engineer

Name & Address of the Office / Department :

DPS Nigahi

(Name & address of the institution)

This certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal

DELHI PUBLIC SCHOOL, NIGAH
POST-NIGAH
DISTT.- SINGRAULI (M. P.) 486884

Manager

Delhi Public School Nigahi
P.O. Nigahi, Distt.-Singrauli (M.P.)
PIN-486884

DISTRICT WATER TESTING LABORATORY**Office of the Assistant Engineer, Public Health Engineering Sub Division, Waidhan (M.P.)****ANALYSIS REPORT**

Report No. :	2026/DWTL/SGRL/830	DATE :07-08-2026
Your Ref.No. :	Q	DATE:05-08-2026
Type of Sample :	Borewell	
Particular of Sender :	Arun Kumar Tiwari	
Particular of Sample :	Treated Water	
Sample No.	Place of collection and details of Sample	Date
I	Delhi Public school Nigahi dist.singrauli (M.P.)	8/5/2026

PARTICULARS TO BE FILLED THE LABORATORY

Date of Receipt : 05/08/2026 Time of Receipt : 04:45 pm

S. No.	Characterstics	Unit	As Per BIS-10500:2012 For Drinking Water		Results			
			Requirement (Desirable Limit)	Requirement (Permissible Limit in the absence of Alternate Source)				

PHYSICAL TEST					1	2	3	4
1	Taste	-	Unobjectionable	Unobjectionable	Unobjectionable	-	-	-
2	Turbidity	NTU	1.00	5.00	1.20	-	-	-
3	Colour	Hazan Units	5.00	15.00	5.00	-	-	-
4	Odour	-	Unobjectionable	Unobjectionable	Unobjectionable	-	-	-

CHEMICAL TEST

5	pH	p H scale	6.5 To 8.5	No Relaxation	6.8	-	-	-
6	Total Hardness as CaCO3	mg/l	200	600	160.00	-	-	-
7	Calcium as Ca	mg/l	75	200	62.00	-	-	-
8	Magnesium as Mg	mg/l	30	100	14.00	-	-	-
9	Total Alkalinity as CaCa3	mg/l	200	600	120.00	-	-	-
10	Chloride as Cl	mg/l	250	1000	80.00	-	-	-
11	Electronic conductivity	us/cm	-	-	29.00	-	-	-
12	Residual chlorine	mg/l	0.2	1.0	0.20	-	-	-

BACTERIOLOGICAL TEST

13	MPN of Coliform	Per 100ML	Nil	Nil	Nil	-	-	-
14	Faecal Coliform	Per 100ML	Nil	Nil	Nil	-	-	-

Notes:-*The figure indicated under the coloumn "Requirement (Desirable Limit)" the limits up to which water is generally acceptable to the consumers. Figures in excess of those mentioned under "Requirement (Desirable Limit)" the water not acceptable, but still may be tolerated in the absence of an alternative and better source but upto the limits indicated under column "Permissible Limit in the absence of an alternative Source" above which the source will have to be rejected (Guideline values for drinking Water as per BIS-10500:2012).

Treated water entering in/in distribution system E.Coli or thermo tolant coliform bacteria & Total coliform bacteria must not be detecable in any 100 ml sample. In case of large supplies, where sufficient sample are examined,must not be present 95%of sample taken through out any 12 month period.

Note : 1. Sample is not collected by us.

2. Not to be produced at court of law .

3. We do not take any responsibility for deviation in test result due to wrong collection of sample .

4. Analysis Report Valid upto one year from the date of issuing .

Remarks if any :

Signature of Analyst

[Signature]
05/08/2026

[Signature]
Lab Incharge

(Authorised Signature)

District Laboratory

Public Health Engineering Deptt. Singrauli

Issued By

[Signature]
PRINCIPAL
DELHI PUBLIC SCHOOL, NIGAH
POST- NIGAH
DISTT.- SINGRAULI (M. P.) 486884

[Signature]
Manager
Delhi Public School Nigahi
P.O. Nigahi, Distt.-Singrauli (M.P.)
PIN-486884